

STATE OF MONTANA
DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION
1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

GENERAL ABSTRACT

Water Right Number: 76M 87132-00 PROVISIONAL PERMIT
Version: 1 -- ORIGINAL RIGHT

Version Status: ACTIVE

Owners: MISSOULA COUNTY AIRPORT AUTHORITY
5225 US HWY 10 W
MISSOULA, MT 59808-9385

Priority Date: SEPTEMBER 8, 1993 at 02:05 P.M.

Enforceable Priority Date: SEPTEMBER 8, 1993 at 02:05 P.M.

Purpose (use): GEOTHERMAL
COOLING

Maximum Flow Rate: 350.00 GPM

Maximum Volume: 272.00 AC-FT

Source Name: GROUNDWATER

Source Type: GROUNDWATER

Point of Diversion and Means of Diversion:

<u>ID</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1		NWNWNW	1	13N	20W	MISSOULA

Period of Diversion: MARCH 1 TO OCTOBER 31

Diversion Means: WELL

Well Depth: 213.00 FEET

Static Water Level: 86.00 FEET

Casing Diameter: 10.00 INCHES

Pump Size: 25.00 HP

Purpose (Use): GEOTHERMAL

Volume: 272.00 AC-FT

Period of Use: MARCH 1 to OCTOBER 31

Place of Use:

<u>ID</u>	<u>Acres</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1			SENE	2	13N	20W	MISSOULA

Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME VOLUME.

87132-00 88483-00

ASSOCIATED RIGHT

THIS RIGHT 76M-P088483-00 USE THE SAME WELL. THE COMBINED FLOW RATE SHALL NOT EXCEED 350 GPM.

GROUNDWATER WASTE & CONTAMINATION

THIS RIGHT IS SUBJECT TO SECTION 85-2-505, MCA, REQUIRING A WELL BE CONSTRUCTED SO IT WILL NOT ALLOW WATER TO BE WASTED OR CONTAMINATE OTHER WATER SUPPLIES OR SOURCES, AND A FLOWING WELL MUST BE CAPPED OR EQUIPPED SO THE FLOW OF THE WATER MAY BE STOPPED WHEN NOT BEING PUT TO BENEFICIAL USE.

GROUNDWATER WELL - ACCESS PORT

THE FINAL COMPLETION OF THE WELL(S) MUST INCLUDE AN ACCESS PORT OF AT LEAST .50 INCH SO THE STATIC LEVEL OF THE WELL MAY BE ACCURATELY MEASURED.