#### STATE OF MONTANA

DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

# **GENERAL ABSTRACT**

Water Right Number:	76M 95096-00 PROVISIONAL PERMIT Version: 1 ORIGINAL RIGHT
Owners:	Version Status: ACTIVE
Owners.	MISSOULA CITY-COUNTY PUBLIC LIBRARY 301 E MAIN ST MISSOULA, MT 59802
Priority Date:	AUGUST 21, 1995 at 03:33 P.M.
Enforceable Priori	ity Date: AUGUST 21, 1995 at 03:33 P.M.
Purpose (use):	GEOTHERMAL
Maximum Flow Rate:	350.00 GPM
Maximum Volume:	1.18 AC-FT
Source Name:	GROUNDWATER
Source Type:	GROUNDWATER
Point of Diversion and Means of Diversion:	
<u>ID</u> 1	Govt LotQtr SecSecTwpRgeCountyNWNESW2213N19WMISSOULA
Period of Diversion Diversion Means: Well Depth: Static Water Level Casing Diameter: Pump Size:	
	THE RELIEF WELL FOR THIS COOLING SYSTEM IS LOCATED IN THE NWNESW, SEC. 22, T32N, R19W, MISSOULA CO.
Purpose (Use): Volume:	GEOTHERMAL 1.18 AC-FT
Period of Use:	MAY 1 to SEPTEMBER 30
Place of Use:	
$\frac{\mathbf{ID}}{1}$ Acres	Govt LotQtr SecSecTwpRgeCountyNWNESW2213N19WMISSOULA

### **Remarks:**

## **ASSOCIATED RIGHT**

THIS PERMIT IS ASOCIATED WITH PERMIT 76M-30045957. THEY SHARE THE SAME POINT OF DIVERSION, PLACE OF USE AND PURPOSE. PERMIT 76M-30045957 ADDS FLOW RATE AND VOLUME. THE TOTAL MAXIMUM FLOW RATE FOR THE COMBINED WATER RIGHTS IS 350 GPM. THE TOTAL MAXIMUM VOLUME FOR THE COMBINED WATER RIGHTS IS 261.4 ACRE-FEET.

#### WATER MEASUREMENT - STATIC WATER MEASUREMENTS REQUIRED

THE APPROPRIATOR SHALL KEEP A WRITTEN RECORD OF THE FLOW RATE AND VOLUME OF ALL WATERS DIVERTED, INCLUDING THE PERIOD OF TIME, AND SHALL SUBMIT SAID RECORDS BY NOVEMBER 30TH OF EACH YEAR AND/OR UPON REQUEST TO THE WATER RESOURCES REGIONAL OFFICE AT THE ADDRESS LISTED BELOW. TOWN & COUNTRY SHOPPING CENTER, 1610 S 3RD ST W, SUITE 103, PO BOX 5004, MISSOULA, MT 59806-5004 PH: 406-721-4284