

STATE OF MONTANA
DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION
1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

GENERAL ABSTRACT

Water Right Number: 76GJ 30009405 PROVISIONAL PERMIT
Version: 2 -- CHANGE AUTHORIZATION
Version Status: ACTIVE

Owners: PHILIPSBURG TOWN OF
PO BOX 339
PHILIPSBURG, MT 59858

Priority Date: MARCH 9, 1989 at 04:00 P.M.

Enforceable Priority Date: MARCH 9, 1989 at 04:00 P.M.

Purpose (use): MUNICIPAL

Maximum Flow Rate: 150.00 GPM

Maximum Volume: 241.95 AC-FT

Source Name: SPRING, GROUNDWATER

Source Type: GROUNDWATER

Point of Diversion and Means of Diversion:

<u>ID</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1		NENESE	25	7N	14W	GRANITE

Period of Diversion: JANUARY 1 TO DECEMBER 31

Diversion Means: DEVELOPED SPRING

Purpose (Use): MUNICIPAL

Volume: 241.95 AC-FT

Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

<u>ID</u>	<u>Acres</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1			E2	23	7N	14W	GRANITE
2				24	7N	14W	GRANITE
3				25	7N	14W	GRANITE
4			E2E2	26	7N	14W	GRANITE
5				36	7N	14W	GRANITE

Remarks:

WATER MEASUREMENT-INLINE FLOW METER REQUIRED

THE APPROPRIATOR SHALL INSTALL A DEPARTMENT APPROVED IN-LINE FLOW METER AT A POINT IN THE DELIVERY LINE APPROVED BY THE DEPARTMENT. WATER MUST NOT BE DIVERTED UNTIL THE REQUIRED MEASURING DEVICE IS IN PLACE AND OPERATING. ON A FORM PROVIDED BY THE DEPARTMENT, THE APPROPRIATOR SHALL KEEP A WRITTEN MONTHLY RECORD OF THE FLOW RATE AND VOLUME OF ALL WATER DIVERTED, INCLUDING THE PERIOD OF TIME. RECORDS SHALL BE SUBMITTED BY NOVEMBER 30 OF EACH YEAR AND UPON REQUEST AT OTHER TIMES DURING THE YEAR. FAILURE TO SUBMIT REPORTS MAY BE CAUSE FOR REVOCATION OF A PERMIT OR CHANGE. THE RECORDS MUST BE SENT TO THE WATER RESOURCES REGIONAL OFFICE. THE APPROPRIATOR SHALL MAINTAIN THE MEASURING DEVICE SO IT ALWAYS OPERATES PROPERLY AND MEASURES FLOW RATE AND VOLUME ACCURATELY.

WATER MEASUREMENT - ANNUAL DATA