

STATE OF MONTANA
DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION
1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

GENERAL ABSTRACT

Water Right Number: 41F 30013630 PROVISIONAL PERMIT
Version: 1 -- ORIGINAL RIGHT
Version Status: ACTIVE

Owners: MT MOONLIGHT BASIN WATER & SEWER LLC
PO BOX 160040
BIG SKY, MT 59716-0040

Priority Date: DECEMBER 7, 2006 at 03:36 P.M.

Enforceable Priority Date: DECEMBER 7, 2006 at 03:36 P.M.

Purpose (use): MUNICIPAL
MUNICIPAL
MUNICIPAL

Maximum Flow Rate: 231.00 GPM

Maximum Volume: 163.20 AC-FT

Maximum Acres: 93.85

Source Name: GROUNDWATER

Source Type: GROUNDWATER

Point of Diversion and Means of Diversion:

<u>ID</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1		NESWNE	23	6S	2E	MADISON

Period of Diversion: JANUARY 1 TO DECEMBER 31

Diversion Means: WELL

Well Depth: 483.00 FEET

Static Water Level: 5.00 FEET

Flowing: NO

Pump Size: 10.00 HP

2		SWNE	23	6S	2E	MADISON
---	--	------	----	----	----	---------

Period of Diversion: JANUARY 1 TO DECEMBER 31

Diversion Means: WELL

Well Depth: 453.00 FEET

Flowing: YES

Pump Size: 10.00 HP

3		NWSESW	14	6S	2E	MADISON
---	--	--------	----	----	----	---------

Period of Diversion: JANUARY 1 TO DECEMBER 31

Diversion Means: WELL

Well Depth: 396.00 FEET

Static Water Level: 131.50 FEET

Flowing: NO

Pump Size: 10.00 HP

Reservoir: OFF STREAM **Reservoir Name** RESERVOIR #1

<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
	SW	14	6S	2E	MADISON

Depth: 18.50 FEET

Surface Area: 5.50 ACRES

Current Capacity: 49.50 ACRE-FEET

Reservoir: OFF STREAM **Reservoir Name** RESERVOIR #2

<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
	SE	14	6S	2E	MADISON

Depth: 29.25 FEET

Surface Area: 2.42 ACRES

Current Capacity: 42.00 ACRE-FEET

Purpose (Use): MUNICIPAL **Purpose Clarification:** GOLF COURSE IRRIGATION

Irrigation Type: SPRINKLER
Climatic Area: 5 - LOW

Remarks:

DEPARTMENT, THE APPROPRIATOR SHALL KEEP A WRITTEN MONTHLY RECORD OF THE FLOW RATE AND VOLUME OF ALL WATER DIVERTED, INCLUDING THE PERIOD OF TIME. RECORDS SHALL BE SUBMITTED BY NOVEMBER 30 OF EACH YEAR AND UPON REQUEST AT OTHER TIMES DURING THE YEAR. FAILURE TO SUBMIT REPORTS MAY BE CAUSE FOR REVOCATION OF A PERMIT OR CHANGE. THE RECORDS MUST BE SENT TO THE WATER RESOURCES REGIONAL OFFICE. THE APPROPRIATOR SHALL MAINTAIN THE MEASURING DEVICE SO IT ALWAYS OPERATES PROPERLY AND MEASURES FLOW RATE AND VOLUME ACCURATELY.

OWNERSHIP UPDATE RECEIVED

OWNERSHIP UPDATE TYPE DOR # 112235 RECEIVED 01/06/2012.