

STATE OF MONTANA
DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION
1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

GENERAL ABSTRACT

Water Right Number: 41F 21774-00 PROVISIONAL PERMIT
Version: 1 -- ORIGINAL RIGHT
Version Status: ACTIVE

Owners: ENNIS, TOWN OF
PO BOX 147
ENNIS, MT 59729

Priority Date: FEBRUARY 8, 1979 at 11:45 A.M.

Enforceable Priority Date: FEBRUARY 8, 1979 at 11:45 A.M.

Purpose (use): MUNICIPAL

Maximum Flow Rate: 350.00 GPM

Maximum Volume: 564.55 AC-FT

Source Name: GROUNDWATER

Source Type: GROUNDWATER

Point of Diversion and Means of Diversion:

<u>ID</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1		NESWNW	4	6S	1W	MADISON

Period of Diversion: JANUARY 1 TO DECEMBER 31

Diversion Means: WELL

Well Depth: 130.00 FEET

Static Water Level: 25.00 FEET

Casing Diameter: 6.62 INCHES

Pump Size: 25.00 HP

Purpose (Use): MUNICIPAL

Volume: 564.55 AC-FT

Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

<u>ID</u>	<u>Acres</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1			N2	4	6S	1W	MADISON
2			S2SE	33	5S	1W	MADISON

Remarks:

GROUNDWATER WASTE & CONTAMINATION

THIS RIGHT IS SUBJECT TO SECTION 85-2-505, MCA, REQUIRING A WELL BE CONSTRUCTED SO IT WILL NOT ALLOW WATER TO BE WASTED OR CONTAMINATE OTHER WATER SUPPLIES OR SOURCES, AND A FLOWING WELL MUST BE CAPPED OR EQUIPPED SO THE FLOW OF THE WATER MAY BE STOPPED WHEN NOT BEING PUT TO BENEFICIAL USE.

GROUNDWATER WELL - ACCESS PORT

THE FINAL COMPLETION OF THE WELL(S) MUST INCLUDE AN ACCESS PORT OF AT LEAST .50 INCH SO THE STATIC LEVEL OF THE WELL MAY BE ACCURATELY MEASURED.