

STATE OF MONTANA
DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION
1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

GENERAL ABSTRACT

Water Right Number: 411 23312-00 PROVISIONAL PERMIT
Version: 3 -- CHANGE AUTHORIZATION
Version Status: ACTIVE

Owners: TOWN VIEW ESTATES WATER USERS ASSN INC
% LEE WOLFE
3920 MCHUGH LN
HELENA, MT 59602-7442

Priority Date: JUNE 26, 1979 at 03:00 P.M.
Enforceable Priority Date: JUNE 26, 1979 at 03:00 P.M.

Purpose (use): MULTIPLE DOMESTIC
Maximum Flow Rate: 150.00 GPM
Maximum Volume: 72.00 AC-FT

Source Name: GROUNDWATER
Source Type: GROUNDWATER

Point of Diversion and Means of Diversion:

<u>ID</u>	<u>Govt Lot</u>	<u>Qtr</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1		SWNWNE	7	11N	3W	LEWIS AND CLARK

Period of Diversion: JANUARY 1 TO DECEMBER 31
Diversion Means: WELL
Well Depth: 340.00 FEET
Static Water Level: 108.00 FEET
Casing Diameter: 6.00 INCHES
Flowing: NO

2		NWNWNE	7	11N	3W	LEWIS AND CLARK
---	--	--------	---	-----	----	-----------------

Period of Diversion: JANUARY 1 TO DECEMBER 31
Diversion Means: WELL
Well Depth: 260.00 FEET
Static Water Level: 45.00 FEET
Casing Diameter: 6.00 INCHES
Flowing: NO

3		NWSWNE	7	11N	3W	LEWIS AND CLARK
---	--	--------	---	-----	----	-----------------

Period of Diversion: JANUARY 1 TO DECEMBER 31
Diversion Means: WELL
Well Depth: 420.00 FEET
Static Water Level: 71.00 FEET
Casing Diameter: 8.00 INCHES
Flowing: NO
Pump Size: 10.00 HP

Purpose (Use): MULTIPLE DOMESTIC
Households:
Volume: 72.00 AC-FT
Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

<u>ID</u>	<u>Acres</u>	<u>Govt Lot</u>	<u>Qtr</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1			E2NWNE	7	11N	3W	LEWIS AND CLARK
	Subdivision:	TOWNVIEW ESTATES					
2			N2SENE	7	11N	3W	LEWIS AND CLARK
	Subdivision:	TOWNVIEW ESTATES					
3			NENE	7	11N	3W	LEWIS AND CLARK
	Subdivision:	TOWNVIEW ESTATES					

Remarks:

Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME OTHER.

23312-00 65217-00

ASSOCIATED RIGHT

THIS WATER RIGHT (WELL NOS. 1 & 2) IS ASSOCIATED TO WATER RIGHT NO. 411-P065217 (WELL NO. 3). THIS IS A MANIFOLD SYSTEM. THE COMBINED APPROPRIATION SHALL NOT EXCEED 260 GPM UP TO 108 ACRE-FEET PER YEAR.

GROUNDWATER WASTE & CONTAMINATION

THIS RIGHT IS SUBJECT TO SECTION 85-2-505, MCA, REQUIRING ALL WELLS BE CONSTRUCTED SO THEY WILL NOT ALLOW WATER TO BE WASTED OR CONTAMINATE OTHER WATER SUPPLIES OR SOURCES, AND ALL FLOWING WELLS SHALL BE CAPPED OR EQUIPPED SO THE FLOW OF THE WATER MAY BE STOPPED WHEN NOT BEING PUT TO BENEFICIAL USE.

GROUNDWATER WELL - ACCESS PORT

THE FINAL COMPLETION OF THE WELL(S) MUST INCLUDE AN ACCESS PORT OF AT LEAST .50 INCH SO THE STATIC LEVEL OF THE WELL MAY BE ACCURATELY MEASURED.

FINAL ORDER

THIS WATER RIGHT IS SUBJECT TO THE FINAL ORDER

WATER MEASUREMENT-WATER USE MEASURING DEVICE

THE APPROPRIATOR SHALL INSTALL A DEPARTMENT APPROVED WATER USE MEASURING DEVICE AT A POINT APPROVED BY THE DEPARTMENT. WATER MUST NOT BE DIVERTED UNTIL THE REQUIRED MEASURING DEVICE IS IN PLACE AND OPERATING. ON A FORM PROVIDED BY THE DEPARTMENT, THE APPROPRIATOR SHALL KEEP A WRITTEN MONTHLY RECORD OF THE FLOW RATE AND VOLUME OF ALL WATER DIVERTED INCLUDING THE PERIOD OF TIME. RECORDS SHALL BE SUBMITTED BY NOVEMBER 30 OF EACH YEAR AND UPON REQUEST AT OTHER TIMES DURING THE YEAR. FAILURE TO SUBMIT REPORTS MAY BE CAUSE FOR REVOCATION OF A PERMIT OR CHANGE. THE RECORDS MUST BE SENT TO THE WATER RESOURCES REGIONAL OFFICE. THE APPROPRIATOR SHALL MAINTAIN THE MEASURING DEVICE SO IT ALWAYS OPERATES PROPERLY AND MEASURES FLOW RATE AND VOLUME ACCURATELY.

WATER MEASUREMENT REQUIREMENT - UNIQUE TYPE

ON A FORM PROVIDED BY THE DEPARTMENT, THE APPROPRIATOR SHALL KEEP WRITTEN MONTHLY RECORD OF THE FLOW RATE AND VOLUME OF ALL WATER DIVERTED, INCLUDING THE PERIOD OF TIME. RECORDS SHALL BE SUBMITTED BY NOVEMBER 30 OF EACH YEAR AND UPON REQUEST AT OTHER TIMES DURING THE YEAR. FAILURE TO SUBMIT REPORTS MAY BE CAUSE FOR REVOCATION OF A PERMIT OR CHANGE. THE RECORDS MUST BE SENT TO THE WATER RESOURCES REGIONAL OFFICE. THE APPROPRIATOR SHALL MAINTAIN THE MEASURING DEVICE SO IT ALWAYS OPERATES PROPERLY AND MEASURES FLOW RATE AND VOLUME ACCURATELY.

PRIVATE AGREEMENT

THERE IS A PRIVATE AGREEMENT BETWEEN INDIVIDUALS WHICH HAS BEEN PLACED IN THE FILE BUT IS NOT NECESSARILY RECOGNIZED BY THIS DEPARTMENT.

WATER MEASUREMENT INFORMATION

THE APPROPRIATOR SHALL MEASURE AND RECORD THE STATIC WATER LEVEL EACH YEAR IN ALL PRODUCTION WELLS ON OR ABOUT THE FIRST OF EACH MONTH., RECORDS MUST INCLUDE THE WATER LEVEL, METHOD OF MEASUREMENT, DATE AND TIME OF MEASUREMENT AND DESCRIPTION OF THE MEASURING POINT ON THE CASING. THE MEASUREMENT SHALL BE RECORDED ONLY AT A TIME WHEN THE WATER LEVEL IS STATIC OR THERE IS NO SIGNIFICANT CHANGE IN MEASUREMENTS TAKEN ONE OR TWO MINUTES APART.

REPLACEMENT WELL INFORMATION

THE NEW WELL IS LOCATED 40 FEET NORTHWEST FROM THE OLD WELL.