

STATE OF MONTANA  
DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION  
1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

# GENERAL ABSTRACT

**Water Right Number:** 41H 47751-00 PROVISIONAL PERMIT  
**Version:** 1 -- ORIGINAL RIGHT  
**Version Status:** ACTIVE

**Owners:** BELGRADE, CITY OF  
91 E CENTRAL AVE  
BELGRADE, MT 59714

**Priority Date:** OCTOBER 22, 1979 at 11:05 A.M.

**Enforceable Priority Date:** OCTOBER 22, 1979 at 11:05 A.M.

**Purpose (use):** MUNICIPAL

**Maximum Flow Rate:** 900.00 GPM

**Maximum Volume:** 908.00 AC-FT

**Source Name:** GROUNDWATER

**Source Type:** GROUNDWATER

**Point of Diversion and Means of Diversion:**

<u>ID</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1		SWSE	1	1S	4E	GALLATIN

**Period of Diversion:** JANUARY 1 TO DECEMBER 31

**Diversion Means:** WELL

**Well Depth:** 205.00 FEET

**Static Water Level:** 57.00 FEET

**Casing Diameter:** 16.00 INCHES

**Pump Size:** 100.00 HP

**Purpose (Use):** MUNICIPAL

**Volume:** 908.00 AC-FT

**Period of Use:** JANUARY 1 to DECEMBER 31

**Place of Use:**

<u>ID</u>	<u>Acres</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1				1	1S	4E	GALLATIN
2			N2	12	1S	4E	GALLATIN
3			S2SE	35	1N	4E	GALLATIN
4			NE	2	1S	4E	GALLATIN

**Remarks:**

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME OTHER.

47751-00 60867-00

**ASSOCIATED RIGHT**

THIS CERTIFICATE IS ASSOCIATED WITH WATER RIGHTS NO. 41HW-006481, 41H-W006482, 41H-P60867, AND 41H-P24875. THEY HAVE OVERLAPPING PLACES OF USE.

**GROUNDWATER WASTE & CONTAMINATION**

THIS RIGHT IS SUBJECT TO SECTION 85-2-505, MCA, REQUIRING A WELL BE CONSTRUCTED SO IT WILL NOT ALLOW WATER TO BE WASTED OR CONTAMINATE OTHER WATER SUPPLIES OR SOURCES, AND A FLOWING WELL MUST BE CAPPED OR EQUIPPED SO THE FLOW OF THE WATER MAY BE STOPPED WHEN NOT BEING PUT TO BENEFICIAL USE.

**GROUNDWATER WELL - ACCESS PORT**

THE FINAL COMPLETION OF THE WELL(S) MUST INCLUDE AN ACCESS PORT OF AT LEAST .50 INCH SO THE STATIC LEVEL OF THE WELL MAY BE ACCURATELY MEASURED.